KFL&A Public Health

Daily Pool Log _____ Name of Establishment _____

Date/ Month/ Year

Note: This is a legal document It must be kept for at least one year		Half an hour before opening, then every 2 hours			Daily					Weekly	Monthly	Indicate each occurrence of an emergency, rescue or equipment break-down recording the incident and the action taken in the Comments section noted below
Signature or initial of operator	**Time**	**Free Available Chlorine** Min. 0.5 mg/l (Min. 1 mg/l when using stabilized chlorine)	**pH** 7.2 to 7.8	**Bromine** Min. 2 mg/l	**# of Bathers**	**Make-up water meter reading**	**Test of emergency telephone**	**Test of ground current leakage device**	**Total Chlorine**	**Cyanuric Acid** Max 60 mg/l	**Total Alkalinity** Min. 80 mg/l	

Comments: _____

_____

_____

_____

_____

At least every thirty days

Check all pool outlet covers and record:

- who conducted the inspection,
- results of the inspection
- action taken.

#7-40-111 03/2003

Note: 1] Pool must be closed when the black disc, 150 mm in diameter, on a white background located at the greatest depth is not clearly visible from 9 metres away.
2] Pool must be closed if the minimum chlorine or bromine levels are not available or if the emergency telephone is not working. Correct problem(s) and reopen.

Personal information on this form is collected under the authority of the Health Protection and Promotion Act S.O. 1983, c.10 and will be used for the administration of Public Health programs. Any questions about the collection of this information should be directed to the Director, Environmental Health, KFL&A Public Health, 221 Portsmouth Avenue, Kingston, Ontario K7M 1V5, 613-549-1232 ext. 243, 1-800-267-7875